



# TURBINE GAS METER CGT

Design and function	page 2
2 General technical data	page 3
3 Measurement outputs	page 4
4 Dimensions and weights	page 5
5 Performance	page 7
6 Pressure loss	page 8
Installation and operation recommendations	page 8





CGT series turbine gas meters are flow meters designed to measure quantity of gases. The meters are mainly used for gas flow ranges from 6.5 up to 6500 m³/h. The CGT series gas meters are applied in measurement systems where high accuracy is required:

- transportation of natural gas
- primary and secondary measurements
- control metering of the natural gas and non aggressive technical gases in industry
- flow measurement for technical purposes

The meters may be applied for measurements of aggressive gases. Any application of that kind should be individually proved and agreed between the client and COMMON S.A.

# 1

# DESIGN AND FUNCTION


The turbine gas meter measures the quantity of gas basing on the flow principle. The gas flows through an integrated flow conditioner, which distributes the flow proportionally in the annular slot and guides it to the turbine wheel. The wheel is driven by the gas flow, and the angular velocity of the rotation is proportional to the gas flow rate. The energy consumption, perceived as pressure loss, is reduced to absolute feasible minimum due to

the application of the flow conditioner, highest precision ball barings, most accurate tolerances of all measuring parts and their proper alignement.

The rotary motion of the turbine wheel is transferred mechanically by gear wheels, and the incorporated gas tight and hermetic magnetic coupling, to the index unit, which is mounted on the top of the body, and shows the operating volume on the totalizer.

The basic components of the COMMON CGT series turbine gas meter are as follows:

- pressure resistant meter body
- inlet flow conditioner
- measuring cartridge with the turbine wheel
- magnetic coupling as the transferring element between measuring cartridge and the index
- •index
- lubricating system (some meters are provided with self lubricating bearings)





# GENERAL TECHNICAL DATA

#### table 1

DN			Maximum	Minimum	LF	
mm	inch	G	flow Q <sub>min</sub> [m³/h]	flow Q <sub>min</sub> [m³/h]	pulse rate U <sub>a</sub> [m³/pulse]	
50	2	40	65	6	0,1	
30		65	100	10	0,1	
		100	160	8		
80	3	160	250	13	1	
		250	400	20		
	100 4	160	250	13		
100		4	250	400	20	1
		400	650	32		
	150 6	400	650	32	1	
150		650	1000	50	ı	
		1000	1600	80	10	
		650	1000	50	1	
200	8	1000	1600	80	10	
		1600	2500	130	10	
		1000				
250	10	1600	2500	130	10	
		2500	4000	200		
		1600	2500	130		
300	12	2500	4000	200	10	
		4000	6500	320		

pressure rating: PN16 to PN110, ANSI150 to ANSI600 other rates on request nominal diameter: DN50 up to DN300 standard range, other on request meter bodies: cast iron or carbon steel details in table 4 6.5 to 6 500 m<sup>3</sup>/h other on reduest flow rangeability: 1:20 minimum at atmospheric pressure Some smaller size meters have reduced ranges. minimum 2 x DN; upstream pipe: meters meet the requirements of the OIML R32 89 Annex A -20°C to +60°C temperature range: gas temperature -25°C to +70°C ambient temperature allowed medias: see table 2 horizontal or vertical operating position:

measurement accuracy:

EU requirements and better

guaranteed at least: 0.2 Qmax - Qmax < ± 1%

Omin -0.2 Omax  $< \pm 2\%$ 

fig.2: Measurement error typical curve

- at low pressure (average I bara) green curve
- at high pressure (over 5 bara)
   blue curve

Gas	Chemical symbol (formula)	Density ρ [kg/m³]	Density related to air	Gas meter execution
Argon	Ar	1,66	1,38	standard IIB
Butane	C <sub>4</sub> H <sub>10</sub>	2,53	2,10	standard IIB
Carbon dioxide	CO <sub>2</sub>	1,84	1,53	standard IIB
Carbon monoxide	CO	1,16	0,97	standard IIB
Ethane	C <sub>2</sub> H <sub>6</sub>	1,27	1,06	standard IIB
Ethylene	C <sub>2</sub> H <sub>4</sub>	1,17	0,98	standard IIB
Helium	He	0,17	0,14	standard IIB
Methane	CH <sub>4</sub>	0,67	0,55	standard IIB
Natural gas	-	~0,75	~0,63	standard IIB
Nitrogen	N <sub>2</sub>	1,16	0,97	standard IIB
Propane	C <sub>3</sub> H <sub>8</sub>	1,87	1,56	standard IIB
Acetylene	C <sub>2</sub> H <sub>2</sub>	1,09	0,91	special IIC
Hydrogen	H <sub>2</sub>	0,084	0,07	special IIC
Air	-	1,20	1,00	standard IIB




table 2: Physical properties of most popular gases that may be measured with the CGT turbine gas meters - density at 101,325 kPa and at 20°C



# MEASUREMENT OUTPUTS

### PRESSURE AND TEMPERATURE OUTPUTS

The operating pressure (reference pressure) can be taken from the pressure taps, marked pr, located on both sides of the meter body.

The meters DN100 and larger can be optionally equipped with two temperature taps for the measurement of the gas temperature.

### PULSE SENSORS

The mechanical index unit indicates the actual volume of the measured gas at operating temperature and operating pressure. It can be rotated axially by 350° in order to facilitate the readings and enable easier connection of pulse sensor plugs.

The index unit is provided with one low frequency LFK reed contact pulse transmitter, as a standard. On request the index may be equipped with:

- LFI inductive pulse sensor (NAMUR)
- HF inductive pulse sensor (NAMUR)




fig. 2. Location of measurement outputs (top view)

HF	LFI	LFK, AFK
Ui = 16 V Dc	Ui = 16 V Dc Ui = 15,5 V DC	
Ii = 25 mA	Ii = 52 mA	li = 52 mA
Pi = 64 mW	Pi = 169 mW	Pi = 169 mW
Li = 50 μH	Li ≈ 40 μH	Li ≈ 0
Ci = 30 nF	Ci = 28 nF	Ci ≈ 0


table 3: Permissible supply parameters of intrinsically safe circuits.

The CGT turbine gas meters may be provided with up to 10 pulse sensors for DN100 - DN300 and up to 8 pulse sensors for DN50 - DN80

LFK - low frequency reed contact pulse sensor	LFK1, LFK2
LFI – low frequency inductive pulse sensor	LFI1, LFI2
HF - inductive pulse sensor in the index unit	HF1, HF2
HF - inductive pulse sensor over the turbine wheel	HF3, HF4
HF - inductive pulse sensor over the reference wheel	HF5, HF6
AFK - anti-fraud reed contact	AFK

The turbine wheel, as a standard, is made of aluminium. This allows to provide each CGT turbine gas meters with HF inductive pulse sensors. There are no extra costs due to the replacement of the turbine wheel.

fig. 3 Pulse sensor pin numbering in sockets 1 and 2 installed in the index



Pin No	Socket 1 pulse sensors	Socket 2 pulse sensors
1 - 4	LFK 1 (standard)	LFK 2
2 - 5	LFI 1	LFI 2
3 - 6	HF 1 or AFK	HF 2

The sockets match the TUCHEL plug No C091 31H006 100 2

fig. 4 Pulse sensor pin numbering in socket of the HF pulse transmitter installed in the meter body

Pin No	HF over turk	oine wheel	HF over reference wheel		
3 - 4	HF 3	HF 4	HF 5	HIF 6	

20 03(+)


The sockets match the TUCHEL plug No C091 31D004 100 2



# DIMENSIONS AND WEIGHTS

## Overall dimensions and weights of CGT turbine gas meters are shown in Table 4

fig.5 Dimensions of the CGT turbine gas meter






table 4

DN L					F F*	Flange		Wei	ght													
D	N	L	Α	В	C   E,	С	E, F*	ANSI	PN	cost iron	steel											
mm	inch	mm	mm	mm	mm	mm		-	kg	kg												
						150	-	16	8,5	11												
						150	150	20	9,5	10												
50	2	150	203	42	58	58	58		300	50	-	11,5										
						226	-	64	-	14												
							600	110	-	14												
				60		146	-	16	20	25												
					1	140	150	20	19,5	24,5												
80	3	240	206	80	95		300	50	-	27,5												
				00		222	-	64	-	28												
							600	110	-	32												
						157	-	16	25	33,5												
						137	150	20	26,5	34,4												
100	4	300	220	101	124		300	50	-	43												
						233	-	64	-	40												
							600	110	-	56												
				125	185	-	16	48	62,5													
					155 180	7	103	150	20	47	62,5											
150	6	450	247	1.5.5		30	300	50	-	80,5												
				155	133	5	155			261	-	64	-	84								
													600	110	-	106						
					212 240	202	-	16	-	80												
						212 240	212 240	212 240	240	202	150	20	-	86								
200	8	600	270	212						240	240	240	240	240	240	240	212 240		300	50	-	116
											282	-	64	-	128							
										600	110	-	153									
						232	-	16	-	142												
					330	232	150	20	-	147												
250	10	750	298	270		70 330	270 330	330		300	50	-	190									
						308	-	64	-	206												
							600	110	-	271												
					300 350		258	-	16	-	215											
						258	150	20	-	235												
300	12	900	323	300		350		300	50	-	290											
						345	-	64	-	300												
			I				600	110	-	360												

<sup>\*</sup> size E is valid for meters PN16, PN20 and ANSI 150, size F is valid for meters PN50, PN64, PN110, ANSI300 and ANSI600



## **PERFORMANCE**

The meter measures the actual quantity of gas flowing at operating conditions (pressure and temperature). This volume is displayed on the index as actual volume in m<sup>3</sup>. The most important factor of the meter size selection (nominal diameter) is the expected minimum and maximum gas flow at the operating conditions.

According to standards the turndown ratio is determined at atmospheric conditions (p = 1.01325 bar).

The measurement range increases with the increase of operating pressure.  $Q_{\min}$  value decreases, and it may be calculated from the following formula:

$$Q_{min\ m} = Q_{min} \cdot \sqrt{\rho_a / \rho_m} [m^3/h]$$

The operating density  $\rho_m$  may to be determined as follows:

$$\rho_{m} \approx (p + 1) \cdot \rho$$
 [kg/m<sup>3</sup>]

### **DEFINITION:**

 $Q_{\min m}$  = minimum flow at operating conditions  $[m^3/h]$ 

Q<sub>min</sub> = minimum flow of the meter at atmospheric conditions [m<sup>3</sup>/h]

p = gauge pressure [bar]

ρ = standard density of the gas
[kg/m³] see table 2 (for natural gas: 0.75 kg/m³)

 $\rho_a$  = standard density of air [kg/m<sup>3</sup>].
(1.2 kg/m<sup>3</sup>)

In order to convert parameters from base to operating conditions, and vice versa, the following formula may be applied:

$$V_m = V_s \cdot k \cdot \frac{P_s}{P_m} \cdot \frac{T_m}{T_s} \approx V_s \cdot Z \cdot \frac{(t_m + 273)}{273 \cdot (p + 1)}$$

#### **DEFINITION:**

V<sub>m</sub> = volume at operating conditions [m<sup>3</sup>/h]

 $V_s$  = volume at base conditions [m<sup>3</sup>/h]

k = relative compressibility factor
k = Z / Zn

Z = real gas factor at operating conditions

 $Z_s$  = real gas factor at base conditions

 $p_s$  = base pressure (1.01325 bar)

p<sub>m</sub> = operating pressure (abs.) at the turbine meter [bar]

p = operating gauge pressure
 at the turbine meter [bar]

 $T_s$  = base gas temperature [K] (273.15K)

 $_{m}$  = operating gas temperature [K]

 $t_m = operating gas temperature [°C]$ 



### PRESSURE LOSS

The inevitable pressure loss during the gas flow through the meter is determined at the atmospheric conditions.

To determine pressure losses at other, higher pressures, the following formula applies:

$$\Delta p_1 = (\frac{\rho}{\rho_2}) \cdot (\frac{p + p_s}{p_s}) \cdot \Delta p$$




fig. 6 Diagram of pressure loss related to  $\rho$  = 1,2  $kg/m^3$ 

### **DEFINITION:**

 $\Delta p_1$  = pressure loss at p  $\Delta p$  = pressure loss from the diagram, fig. 6 p = gauge pressure [bar]  $\rho$  = standard density

of gas [kg/m<sup>3</sup>]  $\rho_a = \text{standard density}$ of air 1,2 kg/m<sup>3</sup>

 $p_s$  = base pressure (1.01325 bar)



# INSTALLATION AND OPERATION RECOMMENDATIONS

- Meters should be shipped in their original package to the place of installation.
- Meters have to be handled with care and protected against falls, direct influence of rain, snow or high humidity.
- The measured gas should be clean, dry and free from solid impurities. It is recommended that the upstream pipe installation is to be equipped with a filter (10 micron).
- Prior to putting into operation in new installations, it is recommended to install a temporary cone sieve.
- Prior to installation the upstream and downstream pipe flanges should be aligned properly.
- Flange gaskets are to be installed so as not to disturb the gas flow.

- The gas flow should be in accordance with the arrow placed on the meter body.
- The piping should be executed so as to avoid unnecessary stresses acting on the meter.
- When used outdoors the meter should be protected against direct weather influence.
- When starting the gas flow through the installation, the valves should be opened slowly to ensure a gradual increase of pressure.

ATTENTION! If valves are opened abruptly or pressure increase takes place in a short time it may happen that the measurement cartridge or the turbine wheel get damaged.

ALWAYS REMEMBER TO START UP THE METERS IN A PROPER WAY!



COMMON S.A. has continuing program of product research and development. Technical specifications and construction may change due to improvements. This publication serves as general information only, and all specifications are subject to confirmation by COMMON S.A.

